


# Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



HYGIENE-INSTITUT · Postfach 10 12 55 · 45812 Gelsenkirchen / GERMANY

SCHOMBURG GmbH & Co. KG

Aquafinstr. 2-8  
32760 Detmold  
GERMANY

Visitor's/Parcel Address:  
Rotthauer Str. 21  
45879 Gelsenkirchen

Telephone +49 (0) 209 9242-0  
Extension +49 (0) 209 9242-277  
Telefax +49 (0) 209 9242-212  
E-Mail r.weiss@hyg.de  
Internet www.hyg.de

Reference-No.: K-305886-18-WR/st  
Contact person: Roland Weiß (Dipl.-Biol.)  
Translation: K-305885-18-WR/st

Gelsenkirchen, 22.11.2018

## TEST CERTIFICATE

according to the DVGW Code of Practice W 347  
"hygienic requirements for cement-bound  
materials for drinking water supply"  
(issue date 2006-05)

**Product:** AQUAFIN-CJ5  
coated joint sheet metal

**Specimen:** all around coated sheets (grey)


### Test result:

The test specimen meet the requirements of the DVGW Code of Practice W 347 according to the test report-no.: K-221120-12-Ko dated 20.09.2012 for the following scopes, as far as the material is qualified technically.

Scope	Products / Components	Assessment
I	mortar lining of cast iron pipes and steel pipes	---
II	concrete pipes $\geq$ DN 300, reservoirs, cementitious coatings of reservoirs	---
III	cement for tiles, joint filler, coating of fittings (e.g. for welding joints)	passed
IV	concrete components in protective areas of drinking water plants I, II, III	passed

This test certificate is valid beginning with the date of issue and is ending by 20.09.2022 as far as there are no changes in the formula.

The Director of the Hygiene-Institute  
on behalf of

  
Dr. rer.nat. Andreas Koch  
Head of the Dept. for water  
hygienic material testing



The assessment was based on the assumption that the used starting substances and monomers used to manufacture the product may completely known and no other substances are present in the product. The validity of this document expires in case of modifications in the composition of the product or the processing conditions. The results and evaluations refer to the groups of test items. This document may not be published without our written permission only complete and unchanged or duplicated.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt-ID: DE125018356  
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Dr. Dirk Waider, Prof. Dr. Lothar Dunemann (geschäftsf. Vorstand)